



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

FLXA21-D-b-c-de-fg-hi-jk-LA-n-NN/qr/st/SCT/uvw/x/z. Analyzer.

IS / I / 1 / ABCD / T4, $-20^{\circ}\text{C} \leq \text{Ta} \leq 55^{\circ}\text{C}$; T6, $-20^{\circ}\text{C} \leq \text{Ta} \leq 40^{\circ}\text{C}$ – IKE039-A12 P.1, IKE039-A12 P.1-1; Entity*

I / 0 / AEx ia / IIC / T4, $-20^{\circ}\text{C} \leq \text{Ta} \leq 55^{\circ}\text{C}$; T6, $-20^{\circ}\text{C} \leq \text{Ta} \leq 40^{\circ}\text{C}$ – IKE039-A12 P.1, IKE039-A12 P.1-1; Entity*

* Approval as intrinsically safe applicable only to Certification Type = EA

NI / I / 2 / ABCD / T4, $-20^{\circ}\text{C} \leq \text{Ta} \leq 55^{\circ}\text{C}$; T6, $-20^{\circ}\text{C} \leq \text{Ta} \leq 40^{\circ}\text{C}$ – IKE039-A12 P.1, IKE039-A12 P.1-1; NIFW

I / 2 / IIC T4, $-20^{\circ}\text{C} \leq \text{Ta} \leq 55^{\circ}\text{C}$; T6, $-20^{\circ}\text{C} \leq \text{Ta} \leq 40^{\circ}\text{C}$ – IKE039-A12 P.1, IKE039-A12 P.1-1; NIFW Type 4X, IP66

Entity Parameters / Nonincendive Field Wiring Parameters:

Housing assembly, supply and output circuit (terminals + and -):

$U_i = 30 \text{ V}$
 $I_i = 100 \text{ mA}$
 $P_i = 0.75 \text{ W}$
 $C_i = 13 \text{ nF}$
 $L_i = 0 \text{ mH}$

Measuring module input circuit (CN2 or CN3 on Back Board):

$U_o = 13.65 \text{ V}$
 $I_o = 50 \text{ mA}$
 $P_o = 0.372 \text{ W}$
 $C_o = 80 \text{ nF}$
 $L_o = 7.7 \text{ mH}$

PH, SC and DO Modules:

$U_i = 13.92 \text{ V}$
 $I_i = 50 \text{ mA}$
 $P_i = 0.374 \text{ W}$
 $C_i = 40 \text{ nF}$

Li = 2.9 mH

Sensor input circuit (PH: terminals 11 through 19, SC: terminal 11 through 16, DO: terminals 11 through 18):

Uo = 11.76 V
Io = 116.5 mA
Po = 0.3424 W
Co = 100 nF
Lo = 1.7 mH

ISC Module:

Ui = 13.92 V
Ii = 50 mA
Pi = 0.374 W
Ci = 40 nF
Li = 7.7 mH

Sensor input circuit (terminals 11 through 17):

Uo = 11.76 V
Io = 60.6 mA
Po = 0.178 W
Co = 100 nF
Lo = 8 mH

b = Enclosure type - P, S, U or E

c = Display - S, D or N

de = Certification type - AB: Type n / nonincendive

EA: Intrinsically safe and nonincendive

fg = Input 1 - P1, C1, C5, D1, S1

hi = Input 2 - P1, C1, C5, D1, S1, NN

jk = Output – AN

n = SI unit setting in software – J, N

qr = Mounting parts – UM, U, PM

st = Hood – H6, H7, H8

uvw = Conduit adapter – CB4, CD4, CF4

z = Other optional specifications not relevant to certification

Equipment Ratings:

When configured with certification option EA - Intrinsically safe, Entity, Class I, Division 1, Groups A, B, C, D, T4, $-20^{\circ}\text{C} \leq T_a \leq 55^{\circ}\text{C}$; T6, $-20^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$; Intrinsically safe, Class I, Zone 0, AEx ia IIC, T4, $-20^{\circ}\text{C} \leq T_a \leq 55^{\circ}\text{C}$; T6, $-20^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$; Class I, Division 2, Groups A, B, C, D, T4, $-20^{\circ}\text{C} \leq T_a \leq 55^{\circ}\text{C}$; T6, $-20^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$, including installation using nonincendive field wiring concept, Class I, Zone 2, Group IIC, T4, $-20^{\circ}\text{C} \leq T_a \leq 55^{\circ}\text{C}$; T6, $-20^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$, including installation using nonincendive field wiring concept; Install per drawings IKE039-A12 P.1, IKE039-A12 P.1-1; Type 4X, IP66

When configured with certification option AB - Class I, Division 2, Groups A, B, C, D, T4, $-20^{\circ}\text{C} \leq T_a \leq 55^{\circ}\text{C}$; T6, $-20^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$, including installation using nonincendive field wiring concept, Class I, Zone 2, Group IIC, T4, $-20^{\circ}\text{C} \leq T_a \leq 55^{\circ}\text{C}$; T6, $-20^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$, including installation using nonincendive field wiring concept; Install per drawings IKE039-A12 P.1, IKE039-A12 P.1-1; Type 4X, IP66

FM Approved for:

Yokogawa Electric Corporation
Tokyo, Japan



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

| | |
|-------------------|------|
| Class 3600 | 2011 |
| Class 3610 | 2010 |
| Class 3611 | 2004 |
| NEMA 250 | 1991 |
| ANSI/ISA 60079-0 | 2009 |
| ANSI/ISA 60079-11 | 2011 |

Original Project ID: 3039632

Approval Granted: June 8, 2012

Subsequent Revision Reports / Date Approval Amended

| Report Number | Date | Report Number | Date |
|---------------|------|---------------|------|
|---------------|------|---------------|------|

FM Approvals LLC

J.E. Marquedant
Group Manager, Electrical

8 June 2012

Date