

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU**

3 EU - Type Examination Certificate Number: **Baseefa17ATEX0019X – Issue 3**

4 Product: **Model 8600D Vortex Flowmeter**

5 Manufacturer: **Emerson – Rosemount, Micro Motion Inc.**

6 Address: **12001 Technology Drive, Eden Prairie, MN 55344. USA**

7 This re-issued certificate extends EU Type Examination Certificate No. Baseefa17ATEX0019X to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Baseefa, Notified Body number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. **See Certificate History**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0: 2018 EN 60079-31: 2014

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following :

Ex II 2D Ex tb IIIC T85°C Db (-20°C ≤ T_a ≤ +70°C)

SGS Baseefa Customer Reference No. **7305**

Project File No. **19/0148**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail baseefa@sgs.com web site www.sgs.co.uk/sgsbaseefa

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN



R S SINCLAIR
TECHNICAL MANAGER
On behalf of SGS Baseefa Limited

13

Schedule

14

Certificate Number Baseefa17ATEX0019X – Issue 3

15 Description of Product

The Model 8600D Vortex Flowmeter is a two-wire, piezoelectric-based flowmeter designed to measure the flow of a fluid within a pipe.

It consists of a sensor board, 4-20mA HART output board, terminal board and optional Liquid Crystal Display (LCD) unit mounted within a coated aluminium alloy or stainless steel enclosure forming the transmitter assembly. This is either mounted on a stainless steel meter body or connected via a coaxial cable to a remote meter body, which contains the piezoelectric sensor. The transmitter converts the signal input to a 4-20mA HART digital output or pulse totalizer signal output.

Connection to the external circuits is achieved by the use of a 4-way terminal block within the transmitter enclosure, entry to which is gained by a threaded conduit entry point. The installation of external connections and the plugging of the unused entry must be carried out using appropriate Ex e or Ex t cable glands or blanking plug components with a minimum degree of protection of IP66 certified by an approved certification body.

Input Parameters

Maximum Working Voltage = 42V d.c.

16 Report Number

See Certificate History

17 Specific Conditions of Use

1. The enclosure may be made from aluminium alloy with a protective polyurethane paint finish which may constitute a potential electrostatic ignition risk. Care should be taken to protect it from external conditions conducive to the build-up of electrostatic charge on such surfaces. The enclosure must not be rubbed or cleaned with a dry cloth.
2. When the equipment is installed, particular precautions must be taken to ensure, taking into account the effect of process fluid temperature, that the ambient temperature of the electrical housing of the equipment meets the marked protection type temperature range.

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject
1.2.7	LVD type requirements
1.2.8	Overloading of equipment (protection relays, etc.)
1.4.1	External effects
1.4.2	Aggressive substances, etc.

19 Drawings and Documents

New drawings submitted for this issue of certificate:

Number	Sheet	Issue	Date	Description
08600-0101	1 to 4	AF	3/12/19	Model 8600D Intrinsically Safe Configuration, ATEX / IECEx, 4-20mA / HART
08800-7609	1 of 1	AB	3/26/18	Schematic Diagram Vortex LCD Board
08800-7611	1 & 2	AL	3/26/18	PCA, Vortex Shrouded, LCD Board, 2 Line
08800-7701	1 to 10	AM	10/18/17	Printed Wiring Board, Phoenix Vortex Sensor Board

Number	Sheet	Issue	Date	Description
08800-7703	1 & 2	AR	03/08/18	8800D HART Output Board Schematic

Current drawings which remain unaffected by this issue:

Number	Sheet	Issue	Date	Description
08800-5506	1 of 1	AD	7/12/17	Filter: EMI
08800-7019	1 to 5	AE	10/22/15	Coplanar Transformer I.S. 250V Spaced
08800-7020	1 to 3	AJ	7/7/15	Transformer, Vortex
08800-7022	1 to 3	AE	2/14/17	Transformer, 250V IS, Vortex
08800-7606	1 of 1	AG	02/14/17	Schematic Diagram, Vortex Terminal Board
08800-7607	1 to 3	AD	02/14/17	PCB, Vortex Terminal Blk Common Electronics
08800-7608	1 to 4	BD	2/15/17	Terminal Block Assembly
08800-7610	1 to 3	AF	08/09/17	Printed Circuit Board, LCD Board, 2 Line
08800-7700	1 to 4	AP	12/19/16	Phoenix Vortex Sensor Board
08800-7702	1 & 2	AY	12/19/16	PCA Phoenix Vortex Sensor Board
08800-7704	1 to 9	AJ	12/19/16	Printed Wiring Board Phoenix Vortex HART Output Board
08800-7705	1 & 2	AP	12/19/16	PCA, Phoenix Vortex HART Output Board

The above drawings are associated and held with IECEx Certificate No. IECEx BAS 12.0053X, and are also associated with IECEx Certificate No's. IECEx BAS 12.0054X & IECEx BAS 17.0018X, and ATEX Certificate No's. Baseefa12ATEX0179X & Baseefa12ATEX0180X.

20 Certificate History

Certificate No.	Date	Comments
Baseefa17ATEX0019X	5 May 2017	The release of the prime certificate. The associated test and assessment against the requirements of EN 60079-0: 2012 + A11: 2013 and EN 60079-31: 2014 is documented in Certification Report No. GB/BAS/ExTR17.0031/00 (held with IECEx BAS 17.0018X Iss. 0).
Baseefa17ATEX0019X Issue 1	20 October 2017	This issue of the certificate permits minor PCB and drawing changes not affecting the original assessment. The above changes are documented in Certification Report No. GB/BAS/ExTR17.0223/00 (held with IECEx Certificate No. IECEx BAS 05.0028X Iss. 13).
Baseefa17ATEX0019X Issue 2	12 February 2018	This issue of the certificate permits the fitting of an alternative piezo sensor in all variants of the equipment, and the fitting of an alternative fire rated cable on remote sensor mounted variants of the equipment. The above changes are assessed not to affect the original assessment of the equipment, and are documented in Certification Report No. GB/BAS/ExTR17.0375/00 (held with IECEx Certificate No. IECEx BAS 05.0028X Iss. 14), Project File No. 17/0626.

Certificate No.	Date	Comments
Baseefa17ATEX0019X Issue 3	11 April 2019	<p>This issue of the certificate permits minor circuit and drawing changes not affecting the previous assessment.</p> <p>This issue also confirms the current design of the Model 8600D Vortex Flowmeter has been reviewed against the requirements of EN IEC 60079-0: 2018 in respect of the differences to EN 60079-0: 2012 + A11: 2013, and none of the differences affect the equipment. The standards listed on page 1 of the certificate were updated.</p> <p>The above changes are documented in Certification Report No. GB/BAS/ExTR19.0066/00 (held with IECEx Certificate No. IECEx BAS 05.0028X Iss. 15).</p>
For drawings applicable to each issue, see original of that issue.		