$1$ EU-TYPE EXAMINATION CERTIFICATE $\langle \mathcal{F}_{\Upsilon} \rangle$						
2	Equipment or Protective systems intend Explosive Atmospheres - Directive 2014	led for use in Potentially				
3	FII-Type Examination Certificate No:	FM14ΔTFX0059X				
4	Equipment or protective system: (Type Reference and Name)	Jupiter JM4 Magnetostrictive Level Transmitter				
5	Name of Applicant:	Magnetrol International Inc.				
6	Address of Applicant:	705 Enterprise Street Aurora, IL 60504 USA				
7	This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and documents therein referred to.					
8	FM Approvals Ltd, notified body number 1725 in accordance with Article 17 of Directive 2014/34/EU of 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.					
	The examination and test results are record	ded in confidential report number:				
	30519	63 dated 30 <sup>th</sup> October 2015				
9 🧹	Compliance with the Essential Health and S 15 of the schedule to this certificate, has be	Safety Requirements, with the exception of those identified in item een assessed by compliance with the following documents:				
	EN 60079-0:2012 + A11:2013, EN and	60079-1:2014, EN 60079-11:2012, EN 60079-31: 2014 EN 60529:1991+ A1:2000				
10	If the sign 'X' is placed after the certificat conditions of use specified in the schedule	e number, it indicates that the equipment is subject to specific to this certificate.				
11	This EU-Type Examination certificate rela equipment or protective system in accord Directive apply to the manufacturing proce- not covered by this certificate.	tes only to the design, examination and tests of the specified ance to the directive 2014/34/EU. Further requirements of the ss and supply of this equipment or protective system. These are				
12	The marking of the equipment or protective	system shall include:				
[5	II 1 G Ex ia IIC T4 Ga Ta = -40 °C to	o +70 °C, IP67				
2	II 2 G Ex db IIB+H <sub>2</sub> T6T1 Gb Ta =	-40 °C to +70 °C, IP67				
	II 2 D Ex to IIIC T85°CT120°C Db	o Ta = -15 °C to +70 °C, IP67				
Nich Depu	olas Ludlam uty Certification Manager, FM Approvals L	td.				
Issue	e date: 24 <sup>th</sup> August 2016					
<u>Tŀ</u>	IIS CERTIFICATE MAY ONLY BE REPROD	DUCED IN ITS ENTIRETY AND WITHOUT CHANGE				
FM Ap T: +44	pprovals Ltd. 1 Windsor Dials, Windsor, Berkshire, UK. S 4 (0) 1753 750 000 F: +44 (0) 1753 868 700 E-mail: <u>ate</u>	SL4 1RS x:@fmapprovals.com www.fmapprovals.com				

Page 1 of 4

F ATEX 020 (Apr/16)





## to EU-Type Examination Certificate No. FM15ATEX0059X

#### 13 Description of Equipment or Protective System:

The Jupiter Model JM4 is a continuous level transmitter for liquid level control, utilizing the engineering principle of magnetostriction and the effect of a magnetic field on the magnetostrictive wire as the basis for operation of the instrument. The primary components are the probe assembly, containing the wire and Preamp PC Board assembly, and the electronics assembly containing all other PC Boards. The Jupiter JM4 Transmitter is available as the Model JM4-51 normal mode (Entity input version) or JM4-52 Fieldbus mode (FISCO input version) and only differs in the Digital PC Board and Wiring PC Board.

A low energy pulse which is generated by the Preamp travels the length of the magnetostrictive wire. A return signal is generated from the location where the magnetic field of the MLI float intersects the wire. A timer measures the elapsed time between the generation of the pulse and the return of the mechanical or acoustic signal. This is detected by the acoustic sensor located in the end of the probe. The software is set up to interpret the time-of-flight data and to display and transmit the process variable data resulting from the measurement.

The Jupiter Model JM4 is a level transmitter with Fieldbus digital communication. The Jupiter Model JM4 uses a nominal input voltage of 24VDC and it provides Fieldbus digital communication. With the FISCO concept the input voltage is limited to 17.5V. A digital display and keypad are optional.

The Jupiter Model JM4 is housed in a dual compartment (die-cast aluminum or investment cast 316SS) enclosure with separate wiring and electronics compartments. The wiring compartment at the top of the transmitter isolates the power/signal conductors from the electronics compartment beneath it by way of an environmentally sealed feed-through. A quick disconnect probe coupling allows probes to be installed without concern for their orientation to the transmitter head. Probe mounting can be provided integrally, directly to the electronics housing, or can be remotely mounted up to 12 feet from the electronics housing.

#### Model Code Structure and Parameters:

#### *JM4-51ab-cde / 2fg-hij-klm-n-o. Jupiter JM4 Magnetostrictive Level Transmitter / JM4 Probe.* Entity Parameters:

Ui = 28.6V, Ii = 140mA, Pi = 1W, Ci = 4.4nF, Li = 2.7µH

a = Safety Option: 0, 1 or 2.

- b = Accessories/Mounting: A, B, C, 0, 1 or 2.
- c = Area Classification: A, B, C, D, 0, 1 or 3. (If c = 3, B or D, b = A or 0 only)
- d = Housing Material: 1 or 2.
- e = Conduit Connection: 0, 1, 2 or 3.
- f = Measurement System: A or C.
- g = Probe Configuration: 1, 2, 8, E, F, H, K, L, M, R, S or T.
- h = Process Connection: 00, 01, 11, 22, 41, 42, 43, 44, 45, 46, 47, 53, 54, 55, 56, 57, 63, 64, 65, 66, 67, CA, CB, CC, DA, DB, DD, DE, EA, EB, ED, EE, FA, FB, FD, FE, FF or FG.
- i = Material of Construction: A, B, C, D, F, L, P or 1.
- j = Probe Options: F, G, N or V.
- k = Installation Considerations: 0, 1, 2, 3, 4, 5, C, E, F, G, H, J or N.
- I = Construction Code: 0, K, L, M or N.
- m = Level/Interface Measurement: 1, 2 or 3.
- n = Float: 00, 11, 12, 13, 21, 22, 23, 31, 32, 41, 42, 51, 52, 61, 62, 99, AA, AB, AC, BA, BB, CA, CB, DA, DB, DC, FA, FB, FC, MA, MB, NA, NB, PA, PB, QA, QB, RA or RB
- o = Probe Length: (3 digit max) in: inches (f = A) or centimeters (f = C).

#### JM4-52ab-cde / 2fg-hij-klm-n-o. Jupiter JM4 Magnetostrictive Level Transmitter / JM4 Probe. FISCO Parameters:

Ui = 17.5V, li = 380mA, Pi = 5.32W, Ci = 440pF, Li = 2.7µH

a = Safety Option: 0, 1 or 2.

b = Accessories/Mounting: A, B, C, 0, 1 or 2.

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Ltd. 1 Windsor Dials, Windsor, Berkshire, UK. SL4 1RS T: +44 (0) 1753 750 000 F: +44 (0) 1753 868 700 E-mail: <u>atex@fmapprovals.com</u> www.fmapprovals.com





#### to EU-Type Examination Certificate No. FM15ATEX0059X

c = Area Classification: A, B, C, D, 0, 1 or 3. (If c = 3, B or D, b = A or 0 only) d = Housing Material: 1 or 2. e = Conduit Connection: 0, 1, 2 or 3. f = Measurement System: A or C. g = Probe Configuration: 1, 2, 8, E, F, H, K, L, M, R, S or T. h = Process Connection: 00, 01, 11, 22, 41, 42, 43, 44, 45, 46, 47, 53, 54, 55, 56, 57, 63, 64, 65, 66, 67, CA, CB, CC, DA, DB, DD, DE, EA, EB, ED, EE, FA, FB, FD, FE, FF or FG. i = Material of Construction: A, B, C, D, F, L, P or 1. j = Probe Options: F, G, N or V. k = Installation Considerations: 0, 1, 2, 3, 4, 5, C, E, F, G, H, J or N. l = Construction Code: 0, K, L, M or N. m = Level/Interface Measurement: 1, 2 or 3. n = Float: 00, 11, 12, 13, 21, 22, 23, 31, 32, 41, 42, 51, 52, 61, 62, 99, AA, AB, AC, BA, BB, CA, CB, DA, DB, DC, FA, FB, FC, MA, MB, NA, NB, PA, PB, QA, QB, RA or RB

o = Probe Length: (3 digit max) in: inches (f = A) or centimeters (f = C).

#### 14 Specific Conditions of Use:

1. The enclosure contains aluminum and is considered to present a potential risk of ignition by impact or friction. Care must be taken during installation and use to prevent impact or friction.

2. To maintain the T4 temperature code care shall be taken to ensure the "Enclosure Temperature" does not exceed 70 °C

3. The risk of electrostatic discharge shall be minimized at installation, following the direction given in the instruction.

4. When equipment is used in explosive dust atmospheres, the end user shall take precautions so that the thermal effects of the process temperature shall limit the equipment enclosure and probe surface temperatures to not exceed the required installation location temperature and shall be between T85C and T120C.

5. For Installation with ambient temperature of 70 °C, refer to the manufacturer's instructions for guidance on proper selection of conductors.

6. Provisions shall be made to provide transient overvoltage protection to a level not to exceed 119Vdc. 7. For the Ex db rated Jupiter JM4, consult the manufacturer for dimensional information on the flameproot joints for repair.

8. All Unused device openings must be closed using a suitably certified plug.

9. Temperature codes for the ratings  $Ex db IIB+H_2$ , are defined by the following table:

Maximum Process Temperature(PT)	Temperature Class	
From 0 °C to 70 °C	<i>T6</i>	
From 71 °C to 90 °C	T5	
From 91 °C to 125 °C	T4	
From 126 °C to 190 °C	ТЗ	
From 191 °C to 290 °C	T2	
From 291 °C to 440 °C	T1	

#### 15 Essential Health and Safety Requirements:

The relevant EHSRs that have not been addressed by the standards listed in this certificate have been identified and assessed in the confidential report identified in item 8.

#### 16 Test and Assessment Procedure and Conditions:

This EU-Type Examination Certificate is the result of testing of a sample of the product submitted, in accordance with the provisions of the relevant specific standard(s), and assessment of supporting documentation. It does not imply an assessment of the whole production.

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Ltd. 1 Windsor Dials, Windsor, Berkshire, UK. SL4 1RS T: +44 (0) 1753 750 000 F: +44 (0) 1753 868 700 E-mail: <u>atex@fmapprovals.com</u> www.fmapprovals.com





## to EU-Type Examination Certificate No. FM15ATEX0059X

Whilst this certificate may be used in support of a manufacturer's claim for CE Marking, FM Approvals Ltd accepts no responsibility for the compliance of the equipment against all applicable Directives in all applications.

This Certificate has been issued in accordance with FM Approvals Ltd's ATEX Certification Scheme.

#### 17 Schedule Drawings

A list of the significant parts of the technical documentation is annexed to this certificate and a copy has been kept by the Notified Body.

#### 18 Certificate History

Details of the supplements to this certificate are described below:

Date	Description
02 <sup>nd</sup> November 2015	Original Issue.
24 <sup>th</sup> August 2016	Supplement 1: Report Reference: 3058192 dated 10 <sup>th</sup> August 2016 Description of change: Update standards, update ratings, update documentation and update certificate to EU format.

# FM Approvals

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Ltd. 1 Windsor Dials, Windsor, Berkshire, UK. SL4 1RS T: +44 (0) 1753 750 000 F: +44 (0) 1753 868 700 E-mail: <u>atex@fmapprovals.com</u> <u>www.fmapprovals.com</u>

# **Blueprint Report**

# Magnetrol International Inc (100000020)

Class No 3610

Original Project I.D.3051963Certificate I.D.FM14ATEX0059X

Drawing No.	<b>Revision Level</b>	Drawing Title	Last Report	Electronic Drawing
005-8084	С	Jupiter JM4 Nameplates	3058192	Yes (pdf)
009-9362	С	Fabrication Digital Board, Model 706	3051963	Yes (pdf)
009-9365	В	Fabrication Display Board, Model 706	3051963	Yes (pdf)
009-9368	А	Fabrication Digital Board, Model 706	3051963	Yes (pdf)
009-9369	А	Fabrication Wiring Board Model 706	3051963	Yes (pdf)
009-9375	В	Foundation Fieldbus Fabrication Wiring Board	3051963	Yes (pdf)
009-9378	А	Fabrication Board, Juniper JM4 Analog	3051963	Yes (pdf)
009-9379	А	Fabrication Board, Juniper JM4 Preamp	3051963	Yes (pdf)
094-6067	L	Eclipse 4X Digital Board	3051963	Yes (pdf)
094-6070	В	Display Board Eclipse 706	3051963	Yes (pdf)
094-6072	D	Digital Board Foundation Fieldbus	3051963	Yes (pdf)
094-6073	D	Wiring Board Eclipse 706	3051963	Yes (pdf)
094-6075	С	Foundation Fieldbus Wiring Board Eclipse 706	3051963	Yes (pdf)
094-6076-001	В	Schematic Jupiter 4X Analog Board	3051963	Yes (pdf)
094-6077-001	В	Schematic Jupiter 4X Preamp Board	3051963	Yes (pdf)
094-6082-001	С	Schematic Jupiter 4X Wiring Board	3051963	Yes (pdf)
099-5074	А	System Drawing Jupiter JM4 Transmitter	3051963	Yes (pdf)
099-6553	W	Jupiter JM4 Agency Drawing	3058192	Yes (pdf)
ORI-46-650	May2016	Jupiter JM4 Installation and Operation Manual	3051963	Yes (pdf)